

Message Text

LIMITED OFFICIAL USE

PAGE 01 STATE 005097
ORIGIN OC-06

INFO OCT-01 EUR-12 NEA-10 ISO-00 CCO-00 FBOE-00 A-01
SY-05 /035 R

DRAFTED BY OC/PE-E:BSKOFFMAN:KM
APPROVED BY A/OC:WENAEHER
OC/PE:GRYOUNTS
A/OC/S:DLACHMAN
A/FBO:WMCCOLLOUGH
A/OC/EUR:DESEDLACEK
A/SY/NSU:RUSSOS
A/SY/FO:AHANRAHAN

-----100624 092201Z /72

R 092012Z JAN 78
FM SECSTATE WASHDC
TO AMEMBASSY ROME
INFO AMEMBASSY BONN
AMCONSUL CASABLANCA

LIMITED OFFICIAL USE STATE 005097

BONN FOR RCO, CASABLANCA FOR RTC

E.O. 11652: N/A

TAGS: AFAC, ABLD, ASEC

SUBJECT: C&R RENOVATION

REF: (A) CRO MEMO TO RSO DATED 11/22/77, (B) RSO
MEMO TO OC/S DATED 11/25/77, (C) RSO SECURITY SURVEY
A-182 DATED 5/20/77, (D) DRAWING PROVIDED WITH REF A

1. IN REVIEW OF ROME'S REQUEST FOR C&R RENOVATION THE
FOLLOWING QUESTIONS ARISE WHICH WILL REQUIRE CLARIFICATION
LIMITED OFFICIAL USE

LIMITED OFFICIAL USE

PAGE 02 STATE 005097

PRIOR TO SCHEDULING SEABEES TO PERFORM THE NECESSARY CON-
STRUCTION.

2. REF C, PARA 2, PAGE 12 OF ENCLOSURE 1 RECOMMENDS THAT
THE STEEL DOOR IN CORRIDOR DESIGNATED 216 IN REF D SHOULD
BE REMOVED AND REPLACED WITH A CLASS FIVE VAULT DOOR.
SINCE THIS DOOR FALLS WITHIN THE VAULTED AREA THERE IS NO

APPARENT REASON FOR A VAULT DOOR IN THIS PROPOSED LOCATION, THEREFORE DOOR 216 SHOULD REMAIN AS IS. THE SECOND CLASS FIVE VAULT DOOR THAT WAS PURCHASED CAN BE USED TO REPLACE THE REAR STAIRWELL FIRE DOOR LISTED IN REF C, PARA 3, PAGE 12 ENCLOSURE 1. THE NEW CLASS FIVE VAULT DOOR CAN BE MODIFIED BY THE INSTALLING SEABEES, TO A QTE NO OUTSIDE HARDWARE UNQTE TYPE DOOR. MODIFICATION INSTRUCTIONS WILL BE PROVIDED TO SEABEES BY SY.

3. REF A, PARA 4 HAS A REQUIREMENT FOR THE CORRIDOR WALL OF ROOM 214 TO BE COVERED WITH STEEL PLATE, ALSO THAT EXISTING DOOR BE BRICKED UP. BELIEVE THAT THIS REQUIREMENT NOT VALID SINCE THIS WALL WILL BE OUTSIDE VAULTED AREA WHEN NEW CLASS FIVE ENTRANCE DOOR IS INSTALLED IN NEW LOCATION.

4. REF C, PARA 2, PAGE 11 OF ENCLOSURE 1 LISTS 18 WINDOW OPENINGS IN THE C&R AREA THAT REQUIRE MODIFICATION TO CONFORM TO VAULT STANDARDS. ALL WINDOW OPENINGS MUST BE MODIFIED PER INSTRUCTION OF DTS INSTALLATION STANDARDS PARA 2.1.17, SUB-PARA C. IT IS NOTED IN PARA 3 OF REF A THAT SHEET STEEL IS AVAILABLE AT POST.

5. SUGGEST THAT ALL RECOMMENDATIONS LISTED REF C BE ACCOMPLISHED AS ONE PROJECT.

LIMITED OFFICIAL USE

LIMITED OFFICIAL USE

PAGE 03 STATE 005097

6. REQUEST POST'S COMMENTS ON THE ABOVE RECOMMENDATIONS; IF ACCEPTABLE DEPARTMENT WILL DEVELOP SPECIFICATIONS, DRAWINGS AND SUBMIT REQUEST FOR SEABEE ASSISTANCE. VANCE

LIMITED OFFICIAL USE

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01 jan 1994
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: n/a
Control Number: n/a
Copy: SINGLE
Draft Date: 09 jan 1978
Decaption Date: 01 jan 1960
Decaption Note:
Disposition Action: RELEASED
Disposition Approved on Date:
Disposition Case Number: n/a
Disposition Comment: 25 YEAR REVIEW
Disposition Date: 20 Mar 2014
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1978STATE005097
Document Source: CORE
Document Unique ID: 00
Drafter: E:BSKOFFMAN:KM
Enclosure: n/a
Executive Order: N/A
Errors: N/A
Expiration:
Film Number: D780013-0905
Format: TEL
From: STATE
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1978/newtext/t19780184/aaaactha.tel
Line Count: 97
Litigation Code IDs:
Litigation Codes:
Litigation History:
Locator: TEXT ON-LINE, ON MICROFILM
Message ID: ceb96de5-c288-dd11-92da-001cc4696bcc
Office: ORIGIN OC
Original Classification: LIMITED OFFICIAL USE
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 2
Previous Channel Indicators: n/a
Previous Classification: LIMITED OFFICIAL USE
Previous Handling Restrictions: n/a
Reference: n/a
Retention: 0
Review Action: RELEASED, APPROVED
Review Content Flags:
Review Date: 12 may 2005
Review Event:
Review Exemptions: n/a
Review Media Identifier:
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
SAS ID: 3806115
Secure: OPEN
Status: NATIVE
Subject: C&R RENOVATION
TAGS: AFAC, ABLD, ASEC
To: ROME
Type: TE
vdkgvwkey: odbc://SAS/SAS.dbo.SAS_Docs/ceb96de5-c288-dd11-92da-001cc4696bcc
Review Markings:
Sheryl P. Walter
Declassified/Released
US Department of State
EO Systematic Review
20 Mar 2014
Markings: Sheryl P. Walter Declassified/Released US Department of State EO Systematic Review 20 Mar 2014